ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

Product Service

CERTIFICATE

No. B 105361 0001 Rev. 00

Holder of Certificate: **LEADER TECHNOLOGY (SHENZHEN) CO., LIMITED**
Unit 04, 7/F, Bright Way Tower, No.33 Mong Kok Rd.
999077 KowLoon
HONG KONG

Production Facility(ies): 099241

Certification Mark:

Product: **Connector**
(Connectors for Photovoltaic System with Fuse Holder)

Model(s): **SY-4F0-15, SY-4F1-15, SY-4F2-15, SY-4F3-15**

Parameters:

Rated Voltage:	1500 V d.c.
Rated Current:	30 A
Protection Class:	II
Degree of Protection:	IP68 (1m, 1h)

Tested according to: IEC 62852(ed.1)
EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64290180306401A
Valid until: 2023-07-05

Date, 2019-07-25 (Symbol Zhao)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

A4 / 07.17